

CERTIFICATE OF MAINTENANCE

FIRE EQUIPMENT

PREMISES	Almac Clinical B9 20 Seagoe Industrial Estate Craigavon BT63 5QD Northern Ireland
ENGINEER	Colin Bickerstaff
CERTIFICATE NUMBER:	C-00118

Quantity	Model	Details
76	Foam	66 Basic Service 4 Extended Service 3 Commission 2 Condemned and replaced
73	CO2	57 Basic Service 15 Overhaul
18	Powder	14 Basic Service 3 Service Exchange
5	Fire Blanket	4 Basic Service

Recommendations

No.	Type	Non-Compliance	Recommendation/New equipment
B9108a	Changing beside label store	Over 20 years old	Replaced with new
B9126	Office Area	Over 20 years old	Replaced with new

Date of Issue:	26/06/2019
----------------	------------

This certificate confirms that the maintenance service of your fire equipment listed above has been carried out in accordance with national standards BS5306: Part 3 and Part 8: 2017 (Extinguishers), BS5839 (Fire Alarms), BS5306: Part 1 1976 (Hose Reels) BS9990 (Dry/Wet Risers & Hydrants) BS5266 (Emergency Lighting).

Next service due in 12 months