

CERTIFICATE OF MAINTENANCE

FIRE EQUIPMENT

PREMISES	Almac Clinical B9 20 Seagoe Industrial Estate Craigavon BT63 5QD Northern Ireland
ENGINEER	
CERTIFICATE NUMBER:	C-00542

Quantity	Model	Details
76	Foam	72 Basic Service 1 Condemned and replaced 2 Extended Service
75	CO2	70 Basic Service 4 Overhaul
17	Powder	9 Service Exchange 6 Basic Service 1 Extended Service
5	Fire Blanket	3 Basic Service 1 Condemned and replaced

Recommendations

No.	Type	Non-Compliance	Recommendation/New equipment
B9029a	Pump House	No coverage	Added new
B9105a	Canteen	Box broken	Replaced with new

Date of Issue:

07/07/2020

The Certificate is to state that the firefighting equipment sited within the named premises has been inspected in accordance with BS5306-3:2017 or I.S 291:2015 Equivalent Testing and refilling completed will have been carried out in accordance with BS5306-9:2015 or I.S 291:2015 Equivalent. Siting of the firefighting equipment meets the requirements of BS5306-8:2012 or I.S 291:2015 Equivalent and any future amendments.

Remedial actions if not completed at the time of service will be noted below on this certification.