

CERTIFICATE OF MAINTENANCE

FIRE EQUIPMENT

PREMISES	Almac Diagnostics MMB2 20 Seagoe Industrial Estate Craigavon BT63 5QD Northern Ireland
ENGINEER	Colin Bickerstaff
CERTIFICATE NUMBER:	C-00378

Quantity	Model	Details
24	Foam	4 Condemned and replaced 14 Basic Service 6 Extended Service
29	CO2	23 Basic Service 5 Overhaul
14	Fire Blanket	14 Basic Service
6	Powder	5 Basic Service 1 Service Exchange

Recommendations

No.	Type	Non-Compliance	Recommendation/New equipment
AMMB001	Entrance	20 years old	Replaced with new
AMMB008	Fire Exit Outside Store 4	20 years old	Replaced with new
AMMB011	Corridor Fire Exit	20 years old	Replaced with new
AMMB054	Fire Exit @ main stairs	20 years old	Replaced with new

Date of Issue:	11/04/2020
----------------	------------

The Certificate is to state that the firefighting equipment sited within the named premises has been inspected in accordance with BS5306-3:2017 or I.S 291:2015 Equivalent Testing and refilling completed will have been carried out in accordance with BS5306-9:2015 or I.S 291:2015 Equivalent. Siting of the firefighting equipment meets the requirements of BS5306-8:2012 or I.S 291:2015 Equivalent and any future amendments.

Remedial actions if not completed at the time of service will be noted below on this certification.