

Fire Extinguisher Certificate of Inspection

Customer Name & Address	Almac Group - Almac Diagnostics MMB2 20 Seagoe Industrial Estate BT63 5QD				
Engineer:	Paul English	Job Number:	J-04692	Order Number:	
Certificate Number:	1119	Date:	13/04/2021		

Quantity	Model	Details
6	Powder	6 Basic Service
24	Foam	21 Basic Service 3 Extended Service
29	CO2	29 Basic Service
13	Fire Blanket	13 Basic Service
0	Water	
0	F Class	

Extinguisher	Serial No.	Location	Type	Size	Action
001 - Foam - Entrance	AMMB001	Entrance	Foam	6	Basic Service
002 - CO2 - Reception	AMMB002	Reception	CO2	2	Basic Service
003 - CO2 - Kitchen	AMMB003	Kitchen	CO2	2	Basic Service
004 - Fire Blanket - Kitchen	AMMB004	Kitchen	Fire Blanket	0	Basic Service
005 - CO2 - Write up area	AMMB005	Write up area	CO2	2	Basic Service
006 - CO2 - I.T. Room	AMMB006	I.T. Room	CO2	2	Basic Service
007 - CO2 - Write-up Area	AMMB007	Write-up Area	CO2	2	Basic Service
008 - Foam - Fire Exit Outside Store 4	AMMB008	Fire Exit Outside Store 4	Foam	6	Basic Service
009 - CO2 - Fire Exit Outside Store 4	AMMB009	Fire Exit Outside Store 4	CO2	2	Basic Service
010 - CO2 - Store 4	AMMB010	Store 4	CO2	2	Basic Service
011 - Foam - Corridor Fire Exit	AMMB011	Corridor Fire Exit	Foam	6	Basic Service
012 - Foam - Fire Exit @ Stair 2	AMMB012	Fire Exit @ Stair 2	Foam	6	Basic Service
013 - Powder - Goods In	AMMB013	Goods In	Powder	9	Basic Service
014 - Powder - Box Outside Goods In	AMMB014	Box Outside Goods In	Powder	9	Basic Service
015 - Powder - Box Outside Goods In	AMMB015	Box Outside Goods In	Powder	9	Basic Service
016 - CO2 - Plant Room 1	AMMB016	Plant Room 1	CO2	5	Basic Service
017 - Foam - Level 2 @ Stairs	AMMB017	Level 2 @ Stairs	Foam	6	Basic Service
018 - Powder - Plant Room 2	AMMB018	Plant Room 2	Powder	9	Basic Service
019 - CO2 - Plant Room 2	AMMB019	Plant Room 2	CO2	5	Basic Service
020 - CO2 - Plant Room - End	AMMB020	Plant Room - End	CO2	5	Basic Service
021 - Foam - Plant Room - End	AMMB021	Plant Room - End	Foam	9	Extended Service
022 - Foam - Corridor	AMMB022	Corridor	Foam	6	Basic Service
023 - CO2 - Corridor	AMMB023	Corridor	CO2	2	Basic Service
024 - CO2 - DNA LAB	AMMB024	DNA LAB	CO2	2	Basic Service
025 - Foam - Genomic Lab 2	AMMB025	Genomic Lab 2	Foam	6	Basic Service
026 - CO2 - Genomic Lab 2	AMMB026	Genomic Lab 2	CO2	2	Basic Service
027 - Fire Blanket - Genomic Lab 2	AMMB027	Genomic Lab 2	Fire Blanket	0	Basic Service

028 - Foam - Genomic Lab 2	AMMB028	Genomic Lab 2	Foam	6	Basic Service
029 - CO2 - Genomic Lab 2	AMMB029	Genomic Lab 2	CO2	2	Basic Service
030 - Fire Blanket - Genomic Lab 2	AMMB030	Genomic Lab 2	Fire Blanket	0	Basic Service
031 - Foam - Lobby	AMMB031	Lobby	Foam	6	Extended Service
032 - CO2 - Lobby	AMMB032	Lobby	CO2	2	Basic Service
033 - Fire Blanket - Kitchen	AMMB033	Kitchen	Fire Blanket	0	Basic Service
034 - CO2 - Write Up Area	AMMB034	Write Up Area	CO2	2	Basic Service
035 - Foam - Genomic Lab 1	AMMB035	Genomic Lab 1	Foam	6	Basic Service
036 - CO2 - Genomic Lab 1	AMMB036	Genomic Lab 1	CO2	2	Basic Service
037 - Fire Blanket - Genomic Lab 1	AMMB037	Genomic Lab 1	Fire Blanket	0	Basic Service
038 - Foam - Genomic lab 1	AMMB038	Genomic lab 1	Foam	6	Basic Service
039 - CO2 - Genomic Lab 1	AMMB039	Genomic Lab 1	CO2	2	Basic Service
040 - Fire Blanket - Genomic Lab 1	AMMB040	Genomic Lab 1	Fire Blanket	0	Basic Service
041 - Foam - Corridor	AMMB041	Corridor	Foam	6	Basic Service
042 - CO2 - O/S Switch Room	AMMB042	O/S Switch Room	CO2	5	Basic Service
043 - Foam - ARRDx plant room	AMMB043	ARRDX plant room	Foam	9	Basic Service
044 - CO2 - ARRDx Plant Room	AMMB044	ARRDX Plant Room	CO2	5	Basic Service
045 - Foam - Level 3 @ stairs	AMMB045	Level 3 @ stairs	Foam	6	Basic Service
046 - Powder - ON Roof	AMMB046	ON Roof	Powder	9	Basic Service
047 - CO2 - Ground Outside Switch Room	AMMB047	Ground Outside Switch Room	CO2	2	Basic Service
048 - Fire Blanket - Sciclone laboratory	AMMB048	Sciclone laboratory	Fire Blanket	0	Basic Service
049 - Foam - Corridor Outside store 3	AMMB049	Corridor Outside store 3	Foam	6	Basic Service
050 - Foam - Fire Exit	AMMB050	Fire Exit	Foam	6	Basic Service
051 - CO2 - Admin Office	AMMB051	Admin Office	CO2	2	Basic Service
052 - Foam - Admin Room	AMMB052	Admin Room	Foam	6	Extended Service
053 - CO2 - Admin Room	AMMB053	Admin Room	CO2	2	Basic Service
054 - Foam - Fire Exit @ main stairs	AMMB054	Fire Exit @ main stairs	Foam	6	Basic Service
056 - Foam - Post AMP Lab	AMMB056	Post AMP Lab	Foam	6	Basic Service
057 - CO2 - Post AMP lab	AMMB057	Post AMP lab	CO2	2	Basic Service
058 - Fire Blanket - Post AMP Lab	AMMB058	Post AMP Lab	Fire Blanket	0	Basic Service
059 - Foam - Post AMP Lab	AMMB059	Post AMP Lab	Foam	6	Basic Service
060 - CO2 - Post AMP Lab	AMMB060	Post AMP Lab	CO2	2	Basic Service
061 - Fire Blanket - Post AMP Lab	AMMB061	Post AMP Lab	Fire Blanket	0	Basic Service
062 - Fire Blanket - Post AMP Lab	AMMB062	Post AMP Lab	Fire Blanket	0	Basic Service
063 - Foam - Post AMP Lab	AMMB063	Post AMP Lab	Foam	6	Basic Service
064 - CO2 - Post AMP Lab	AMMB064	Post AMP Lab	CO2	2	Basic Service
065 - Foam - Post AMP Lab	AMMB065	Post AMP Lab	Foam	6	Basic Service
066 - CO2 - Post AMP Lab	AMMB066	Post AMP Lab	CO2	2	Basic Service
067 - Fire Blanket - Post AMP Lab	AMMB067	Post AMP Lab	Fire Blanket	0	Basic Service
068 - CO2 - Dark Room	AMMB068	Dark Room	CO2	2	Basic Service
069 - Fire Blanket - General Consumables Store	AMMB069	General Consumables Store	Fire Blanket	0	Basic Service
070 - Fire Blanket - Autoclave Lab	AMMB070	Autoclave Lab	Fire Blanket	0	Basic Service
072 - Powder - Waste Compound	AMMB072	Waste Compound	Powder	9	Basic Service
073 - Foam - Mezzanine	AMMB073	Mezzanine	Foam	6	Basic Service
074 - CO2 - Mezzanine	AMMB074	Mezzanine	CO2	2	Basic Service

General Comments



FireHow Limited
Suite 10 Avonmore House
15 Church Square
Banbridge BT32 4AP
t 028406 48444 m 44 07846633129
e: colin.bickerstaff@firehow.co.uk
w: www.firehow.co.uk
Company Registration No. NI 648838
VAT No. 280425024

--

Special Remarks

No Access to IT we couldn't get anyone from IT to access room extinguisher down as serviced but will pick it up next time at Almac this week

I/We have inspected and serviced as necessary to BS5306-3 (UK) and IS 291 (ROI), the fire extinguishers on this certificate. These were left in good working order, except where indicated on this certificate. Please Note Comments Listed Under Special Remarks.

Customer Signature:		Inspector's Signature:		Time In:	08:45
Customer Print Name:	Lynn Ryan	Print Name:	Paul English	Time Out	14:51
Position:	Manager				

FIREHØW

FireHow Limited

Suite 10 Avonmore House

15 Church Square

Banbridge BT32 4AP

t 028406 48444 m 44 07846633129

e: colin.bickerstaff@firehow.co.uk

w: www.firehow.co.uk

Company Registration No. NI 648838

VAT No. 280425024

Photos

