

CERTIFICATE OF MAINTENANCE

FIRE EQUIPMENT

PREMISES	Almac Engineering (group) B7 20 Seagoe Industrial Estate Craigavon BT63 5QD Northern Ireland
ENGINEER	Colin Bickerstaff
CERTIFICATE NUMBER:	C-00487

Quantity	Model	Details
20	CO2	16 Basic Service 3 Overhaul
14	Foam	7 Basic Service 4 Extended Service 3 Condemned and replaced
2	Powder	2 Service Exchange
2	Fire Blanket	2 Basic Service

Recommendations

No.	Type	Non-Compliance	Recommendation/New equipment
B7016	Fire exit at plant	20 years old	Replaced with new
B7024	Mobile Office 1 Ground Floor	20 years old	Replaced with new
B7034	welding Container	20 years old	Replaced with new

Date of Issue:	11/06/2019
----------------	------------

This certificate confirms that the maintenance service of your fire equipment listed above has been carried out in accordance with national standards BS5306: Part 3 and Part 8: 2017 (Extinguishers), BS5839 (Fire Alarms), BS5306: Part 1 1976 (Hose Reels) BS9990 (Dry/Wet Risers & Hydrants) BS5266 (Emergency Lighting).

Next service due in 12 months