

CERTIFICATE OF MAINTENANCE

FIRE EQUIPMENT

PREMISES	Almac Engineering (group) B7 20 Seagoe Industrial Estate Craigavon BT63 5QD Northern Ireland
ENGINEER	Colin Bickerstaff
CERTIFICATE NUMBER:	C-00516

Quantity	Model	Details
20	CO2	17 Basic Service 3 Overhaul
14	Foam	14 Basic Service
2	Powder	2 Basic Service
2	Fire Blanket	1 Basic Service 1 Condemned and replaced

Recommendations

No.	Type	Non-Compliance	Recommendation/New equipment
B7035	Welding Container	Box broken	Replaced with new

Date of Issue:	04/08/2020
----------------	------------

The Certificate is to state that the firefighting equipment sited within the named premises has been inspected in accordance with BS5306-3:2017 or I.S 291:2015 Equivalent Testing and refilling completed will have been carried out in accordance with BS5306-9:2015 or I.S 291:2015 Equivalent. Siting of the firefighting equipment meets the requirements of BS5306-8:2012 or I.S 291:2015 Equivalent and any future amendments.

Remedial actions if not completed at the time of service will be noted below on this certification.