

Fire Extinguisher Certificate of Inspection

Customer Name & Address	Almac Group - Almac Group, Ballyhannon House 07 Ballyhannon Lane Ballyhannon Road Portadown BT63 5YF				
Engineer:	Colin Bickerstaff	Job Number:	J-03756	Order Number:	
Certificate Number:	1149	Date:	18/01/2021		

Quantity	Model	Details
0	Powder	
2	Foam	
1	CO2	1 Basic Service
1	Fire Blanket	1 Basic Service
0	Water	
0	F Class	

Extinguisher	Serial No.	Location	Type	Size	Action
001 - Foam - Under The Stairs	ATH001	Under The Stairs	Foam	6	Condemned/Replaced
002 - Foam - utility Room	ATH002	utility Room	Foam	6	Condemned/Replaced
003 - CO2 - Utility Room	ATH003	Utility Room	CO2	2	Basic Service
004 - Fire Blanket - Utility Room	ATH004	Utility Room	Fire Blanket	0	Basic Service

General Comments
X2 foams 20years old replaced with new X2 Enviromental disposal

Special Remarks

I/We have inspected and serviced as necessary to BS5306; parts 3 & 8 2009, the fire extinguishers on this certificate. These were left in good working order, except where indicated on this certificate. Please Note Comments Listed Under Special Remarks.

Customer Signature:	<i>none required</i>	Inspector's Signature:	<i>CB</i>	Time In:	14:03
Customer Print Name:	Dawn Balmer	Print Name:	Colin Bickerstaff	Time Out	15:05
Position:	HSE				

FIREHØW

FireHow Limited

Suite 10 Avonmore House

15 Church Square

Banbridge BT32 4AP

t 028406 48444 m 44 07846633129

e: colin.bickerstaff@firehow.co.uk

w: www.firehow.co.uk

Company Registration No. NI 648838

VAT No. 280425024

Photos

