

CERTIFICATE OF MAINTENANCE

FIRE EQUIPMENT

PREMISES	Almac Pharma B1 20 Seagoe Industrial Estate Craigavon BT63 5QD Northern Ireland
ENGINEER	Colin Bickerstaff
CERTIFICATE NUMBER:	C-00108

Quantity	Model	Details
58	Foam	47 Basic Service 6 Extended Service 5 Condemned and replaced
70	CO2	46 Basic Service 24 Overhaul
21	Powder	11 Basic Service 9 Service Exchange
8	Fire Blanket	8 Basic Service

Recommendations

No.	Type	Non-Compliance	Recommendation/New equipment
AB1031	Main Reception	Dented body	Replaced with new
AB1050	Micro Lab	20 years old and broken hose	Replaced with new
AB1065	Corridor	20 years old	Replaced with new
AB1107	Building 1C	20 years old	Replaced with new
AB1109	Building 1C	20 years old	Replaced with new

Date of Issue:	23/05/2019
----------------	------------

This certificate confirms that the maintenance service of your fire equipment listed above has been carried out in accordance with national standards BS5306: Part 3 and Part 8: 2017 (Extinguishers), BS5839 (Fire Alarms), BS5306: Part 1 1976 (Hose Reels) BS9990 (Dry/Wet Risers & Hydrants) BS5266 (Emergency Lighting).

Next service due in 12 months