

CERTIFICATE OF MAINTENANCE

FIRE EQUIPMENT

PREMISES	Almac Pharma B12 20 Seagoe Industrial Estate Craigavon BT63 5QD Northern Ireland
ENGINEER	Paul English
CERTIFICATE NUMBER:	C-00316

Quantity	Model	Details
18	Foam	15 Basic Service 3 Extended Service
11	CO2	9 Basic Service 2 Overhaul

Recommendations

No.	Type	Non-Compliance	Recommendation/New equipment
Date of Issue:	05/03/2020		

The Certificate is to state that the firefighting equipment sited within the named premises has been inspected in accordance with BS5306-3:2017 or I.S 291:2015 Equivalent Testing and refilling completed will have been carried out in accordance with BS5306-9:2015 or I.S 291:2015 Equivalent. Siting of the firefighting equipment meets the requirements of BS5306-8:2012 or I.S 291:2015 Equivalent and any future amendments.

Remedial actions if not completed at the time of service will be noted below on this certification.