

## CERTIFICATE OF MAINTENANCE

### FIRE EQUIPMENT

PREMISES	Almac Pharma B13/13A Pharma Services Summerisland Road Annaghmore Craigavon Northern Ireland
ENGINEER	Colin Bickerstaff
CERTIFICATE NUMBER:	C-00087

Quantity	Model	Details
11	Foam	8 Basic Service 2 Extended Service 1 Commission
3	CO2	3 Basic Service
1	Fire Blanket	1 Basic Service

### Recommendations

No.	Type	Non-Compliance	Recommendation/New equipment
AU13015	13a at roller door	No cover in area	

Date of Issue: **10/09/2019**

This certificate confirms that the maintenance service of your fire equipment listed above has been carried out in accordance with national standards BS5306: Part 3 and Part 8: 2017 (Extinguishers), BS5839 (Fire Alarms), BS5306: Part 1 1976 (Hose Reels) BS9990 (Dry/Wet Risers & Hydrants) BS5266 (Emergency Lighting).

Next service due in 12 months