

## CERTIFICATE OF MAINTENANCE

### FIRE EQUIPMENT

PREMISES	Almac Pharma B14A 20 Seagoe Industrial Estate Craigavon BT63 5QD Northern Ireland
ENGINEER	Colin Bickerstaff
CERTIFICATE NUMBER:	C-00470

Quantity	Model	Details
4	Foam	1 Condemned and replaced 3 Basic Service
2	CO2	2 Basic Service
1	Powder	1 Basic Service

### Recommendations

No.	Type	Non-Compliance	Recommendation/New equipment
AB14A001	Fire Exit	Dented body	Replaced with new

Date of Issue:	19/05/2020
----------------	------------

The Certificate is to state that the firefighting equipment sited within the named premises has been inspected in accordance with BS5306-3:2017 or I.S 291:2015 Equivalent Testing and refilling completed will have been carried out in accordance with BS5306-9:2015 or I.S 291:2015 Equivalent. Siting of the firefighting equipment meets the requirements of BS5306-8:2012 or I.S 291:2015 Equivalent and any future amendments.

Remedial actions if not completed at the time of service will be noted below on this certification.