

Fire Extinguisher Certificate of Inspection

Customer Name & Address	Almac Group - Almac Sciences B16 20 Seagoe Industrial Estate BT63 5QD				
Engineer:	Paul English	Job Number:	J-04964	Order Number:	
Certificate Number:	1233	Date:	09/03/2021		

Quantity	Model	Details
10	Powder	8 Basic Service
31	Foam	22 Basic Service 5 Extended Service
42	CO2	37 Basic Service
6	Fire Blanket	6 Basic Service
0	Water	
0	F Class	

Extinguisher	Serial No.	Location	Type	Size	Action
001 - Foam - Spares in hut	AB16001	Spares in hut	Water	6	Basic Service
002 - Powder - Spares in Hut	AB16002	Spares in Hut	Powder	6	Basic Service
003 - Foam - Spares in Hut	AB16003	Spares in Hut	Foam	6	No Access
004 - Foam - Spares in Hut	AB16004	Spares in Hut	Foam	9	No Access
005 - CO2 - Spares In Hut	AB16005	Spares In Hut	CO2	5	No Access
006 - CO2 - Spares In Hut	AB16006	Spares In Hut	CO2	2	No Access
007 - Powder - Spares In Hut	AB16007	Spares In Hut	Powder	9	No Access
008 - Foam - Lab Entrance at boiler	AB16008	Lab Entrance at boiler	Foam	6	No Access
009 - CO2 - Lab office at boiler	AB16009	Lab office at boiler	CO2	2	No Access
010 - Powder - LAB	AB16010	LAB	Powder	6	Basic Service
011 - CO2 - Lab	AB16011	Lab	CO2	2	Basic Service
012 - Fire Blanket - LAB	AB16012	LAB	Fire Blanket	0	Basic Service
013 - CO2 - Boiler House	AB16013	Boiler House	CO2	5	Basic Service
014 - Powder - Boiler House	AB16014	Boiler House	Powder	9	Basic Service
015 - CO2 - Generator 16	AB16015	Generator 16	CO2	5	No Access
016 - Powder - Box @ Plant Room 6	AB16016	Box @ Plant Room 6	Powder	9	Basic Service
017 - Powder - Box @ Plant Room 6	AB16017	Box @ Plant Room 6	Powder	9	Basic Service
018 - CO2 - Plant Room 2	AB16018	Plant Room 2	CO2	5	Basic Service
019 - Foam - Plant Room 2	AB16019	Plant Room 2	Foam	6	Extended Service
020 - Foam - Side Entrance Biocatalysis Lab	AB16020	Side Entrance Biocatalysis Lab	Foam	6	Extended Service
021 - CO2 - Side Entrance biocatalysis Lab	AB16021	Side Entrance biocatalysis Lab	CO2	2	Basic Service
022 - Powder - biocatalysis Lab	AB16022	biocatalysis Lab	Powder	6	Service Exchange
023 - Foam - biocatalysis Lab	AB16023	biocatalysis Lab	Foam	6	Extended Service
024 - CO2 - biocatalysis Lab	AB16024	biocatalysis Lab	CO2	2	Basic Service
025 - Fire Blanket - biocatalysis Lab	AB16025	biocatalysis Lab	Fire Blanket	0	Basic Service
026 - Fire Blanket - biocatalysis Lab	AB16026	biocatalysis Lab	Fire Blanket	0	Basic Service
027 - Foam - Building 16 main Entrance	AB16027	Building 16 main Entrance	Foam	9	Basic Service

028 - CO2 - Building 16 main Entrance	AB16028	Building 16 main Entrance	CO2	2	Basic Service
029 - CO2 - Office	AB16029	Office	CO2	2	Basic Service
030 - CO2 - Tea Room	AB16030	Tea Room	CO2	2	Basic Service
031 - Fire Blanket - Tea Room	AB16031	Tea Room	Fire Blanket	0	Basic Service
032 - Foam - Fire Exit at lockers	AB16032	Fire Exit at lockers	Foam	9	Basic Service
034 - CO2 - Dispensary	AB16034	Dispensary	CO2	2	Basic Service
034 - CO2 - Dispensary	AB16034	Dispensary	CO2	2	Basic Service
035 - Foam - Corridor Fire Exit	AB16035	Corridor Fire Exit	Foam	9	Basic Service
036 - CO2 - Corridor Fire Exit	AB16036	Corridor Fire Exit	CO2	5	Basic Service
037 - CO2 - Corridor Fire Exit	AB16037	Corridor Fire Exit	CO2	5	Basic Service
038 - CO2 - Switch Room	AB16038	Switch Room	CO2	5	Basic Service
039 - CO2 - Micronisor Suite	AB16039	Micronisor Suite	CO2	2	Basic Service
040 - Foam - Main corridor	AB16040	Main corridor	Foam	9	Basic Service
041 - CO2 - Main corridor	AB16041	Main corridor	CO2	2	Basic Service
042 - Foam - Plant Room 1	AB16042	Plant Room 1	Foam	9	Basic Service
043 - CO2 - Plant Room 1	AB16043	Plant Room 1	CO2	5	Basic Service
044 - CO2 - Isolation Room 1	AB16044	Isolation Room 1	CO2	5	Basic Service
045 - CO2 - Corridor Fire Exit	AB16045	Corridor Fire Exit	CO2	2	Basic Service
046 - Foam - Corridor Fire Exit	AB16046	Corridor Fire Exit	Foam	9	Basic Service
047 - Powder - Analytical Lab	AB16047	Analytical Lab	Powder	6	Basic Service
048 - Foam - Analytical Lab	AB16048	Analytical Lab	Foam	9	Basic Service
049 - CO2 - Analytical Lab	AB16049	Analytical Lab	CO2	2	Basic Service
050 - Fire Blanket - Analytical lab	AB16050	Analytical lab	Fire Blanket	0	Basic Service
051 - Foam - 1st Floor Lobby	AB16051	1st Floor Lobby	Foam	9	Basic Service
052 - CO2 - 1st Floor lobby	AB16052	1st Floor lobby	CO2	2	Basic Service
053 - Foam - Plant room 3	AB16053	Plant room 3	Foam	9	Basic Service
054 - D Class - Plant Room 3	AB16054	Plant Room 3	D Class	9	Basic Service
055 - CO2 - Plant Room 3	AB16055	Plant Room 3	CO2	5	Basic Service
056 - CO2 - Plant room 5	AB16056	Plant room 5	CO2	5	Basic Service
057 - Foam - 1st Floor @ Lift	AB16057	1st Floor @ Lift	Foam	9	Basic Service
058 - CO2 - 1st Floor @ Lift	AB16058	1st Floor @ Lift	CO2	2	Basic Service
059 - Foam - Production Room 2	AB16059	Production Room 2	Foam	9	Basic Service
060 - CO2 - Production Room 2	AB16060	Production Room 2	CO2	5	Basic Service
061 - D Class - Production Room 2	AB16061	Production Room 2	D Class	9	Basic Service
062 - Foam - Production Room 2	AB16062	Production Room 2	Foam	100	Basic Service
063 - CO2 - Production Room 2 ground floor	AB16063	Production Room 2 ground floor	CO2	5	Basic Service
064 - Powder - Production Room 2 ground floor	AB16064	Production Room 2 ground floor	Powder	9	Basic Service
065 - Foam - Ground Floor Fire	AB16065	Ground Floor Fire	Foam	9	Basic Service
068 - Foam - Plant Room 5	AB16068	Plant Room 5	Foam	9	Basic Service
069 - CO2 - Plant Room 5	AB16069	Plant Room 5	CO2	5	Basic Service
070 - Foam - Plant Room 5	AB16070	Plant Room 5	Foam	9	Basic Service
071 - Foam - Door to Roof	AB16071	Door to Roof	Foam	9	Basic Service
072 - CO2 - Door to Roof	AB16072	Door to Roof	CO2	2	Basic Service
073 - Foam - Production Room 1	AB16073	Production Room 1	Foam	9	Basic Service
074 - CO2 - Production Room 1	AB16074	Production Room 1	CO2	5	Basic Service
075 - Foam - production Room 1	AB16075	production Room 1	Powder	100	Basic Service
076 - D Class - Production Room 1	AB16076	Production Room 1	D Class	12	Basic Service

077 - Foam - Production Room 1 1st Floor	AB16077	Production Room 1 1st Floor	Foam	9	Basic Service
078 - CO2 - production Room 1 1st floor	AB16078	production Room 1 1st floor	CO2	5	Basic Service
079 - Foam - Mobile 1	AB16079	Mobile 1	Foam	6	No Access
080 - CO2 - Mobile 1	AB16080	Mobile 1	CO2	2	No Access
081 - Foam - 2nd Floor Lobby	AB16081	2nd Floor Lobby	Foam	9	Extended Service
082 - CO2 - Plant Room 4	AB16082	Plant Room 4	CO2	5	Basic Service
083 - Foam - Plant Room 4	AB16083	Plant Room 4	Foam	9	Basic Service
084 - CO2 - Rack Room 2 - 1972X	AB16084	Rack Room 2 - 1972X	CO2	5	Basic Service
085 - Foam - Monitoring room 2	AB16085	Monitoring room 2	Foam	9	Extended Service
086 - CO2 - Monitoring Room 2	AB16086	Monitoring Room 2	CO2	2	Basic Service
087 - CO2 - Rack Room 1-1972X	AB16087	Rack Room 1-1972X	CO2	5	Basic Service
088 - Foam - Monitoring Room 1	AB16088	Monitoring Room 1	Foam	6	Basic Service
089 - CO2 - Monitoring Room 1	AB16089	Monitoring Room 1	CO2	2	Basic Service
091 - CO2 - Plant Room 7	AB16091	Plant Room 7	CO2	5	Basic Service
092 - Fire Blanket - Plant Room 7	AB16092	Plant Room 7	Fire Blanket	0	Basic Service
093 - Powder - Plant room 7	AB16093	Plant room 7	Powder	9	Basic Service
094 - CO2 - Isolation Room 2	AB16094	Isolation Room 2	CO2	5	Basic Service
095 - Foam - Isolation room 2	AB16095	Isolation room 2	Foam	6	Basic Service
096 - D Class - Production room 2 ground floor	AB16096	Production room 2 ground floor	D Class	9	Basic Service
097 - D Class - Production room 2 upper level	AB16097	Production room 2 upper level	D Class	9	Basic Service
098 - Foam - Production room 2 upper level	AB16098	Production room 2 upper level	Foam	9	Basic Service
099 - CO2 - Production room 2 upper level	AB16099	Production room 2 upper level	CO2	5	Basic Service
44a - D Class - Isolation room 1	AB16044a	Isolation room 1	D Class	9	Basic Service

General Comments

Extinguishers
 79, 80
 No longer exist mobile hut removed
 Extinguisher
 15
 No longer exist Geerator gone due to building works
 Spare extinguishers 3,4,5,6,7, no longer exist
 Lab extinguisher 8,9
 No longer exist
 Lots of building work going on at this site hence some places are no longer there and extinguishers have been removed

Special Remarks

I/We have inspected and serviced as necessary to BS5306-3 (UK) and IS 291 (ROI), the fire extinguishers on this certificate.
 These were left in good working order, except where indicated on this certificate.
 Please Note Comments Listed Under Special Remarks.

Customer Signature:		Inspector's Signature:		Time In:	08:42
Customer Print Name:	David Emerson	Print Name:	Paul English	Time Out	16:00
Position:	Manager				

FIREHØW

FireHow Limited

Suite 10 Avonmore House

15 Church Square

Banbridge BT32 4AP

t 028406 48444 m 44 07846633129

e: colin.bickerstaff@firehow.co.uk

w: www.firehow.co.uk

Company Registration No. NI 648838

VAT No. 280425024

Photos

