

CERTIFICATE OF MAINTENANCE

FIRE EQUIPMENT

PREMISES	Almac Sciences B 23 A Breagh Drive Seagoe Industrial Estate Craigavon BT63 5QD Northern Ireland
ENGINEER	Jeff Dodds
CERTIFICATE NUMBER:	C-00068

Quantity	Model	Details
9	Foam	9 Basic Service
10	CO2	10 Basic Service
3	Fire Blanket	3 Basic Service

Recommendations

No.	Type	Non-Compliance	Recommendation/New equipment
AB23A020	Boiler house		

Date of Issue:	28/02/2019
----------------	------------

This certificate confirms that the maintenance service of your fire equipment listed above has been carried out in accordance with national standards BS5306: Part 3 and Part 8: 2017 (Extinguishers), BS5839 (Fire Alarms), BS5306: Part 1 1976 (Hose Reels) BS9990 (Dry/Wet Risers & Hydrants) BS5266 (Emergency Lighting).

Next service due in 12 months