

Fire Extinguisher Certificate of Inspection

Customer Name & Address	Almac Group - Almac Sciences B 23 A Breagh Drive Seagoe Industrial Estate BT63 5QD				
Engineer:	Paul English	Job Number:	J-03821	Order Number:	
Certificate Number:	808	Date:	26/02/2021		

Quantity	Model	Details
0	Powder	
9	Foam	9 Basic Service
10	CO2	8 Basic Service
3	Fire Blanket	3 Basic Service
0	Water	
0	F Class	

Extinguisher	Serial No.	Location	Type	Size	Action
001 - Foam - Entrance	AB23A001	Entrance	Foam	6	Basic Service
002 - CO2 - Switch @ Lift	AB23A002	Switch @ Lift	CO2	2	No Access
003 - Foam - LHS lab	AB23A003	LHS lab	Foam	6	Basic Service
004 - CO2 - LHS Lab	AB23A004	LHS Lab	CO2	2	Basic Service
005 - Fire Blanket - LHS LAB	AB23A005	LHS LAB	Fire Blanket	0	Basic Service
006 - Foam - Fire Exit	AB23A006	Fire Exit	Foam	6	Basic Service
007 - Foam - RHS lab	AB23A007	RHS lab	Foam	6	Basic Service
008 - CO2 - RHS Lab	AB23A008	RHS Lab	CO2	2	Basic Service
009 - Fire Blanket - RHS Lab	AB23A009	RHS Lab	Fire Blanket	0	Basic Service
010 - Foam - Fire/Exit	AB23A010	Fire/Exit	Foam	6	Basic Service
011 - Foam - 1st Floor	AB23A011	1st Floor	Foam	6	Basic Service
012 - CO2 - 1st Floor	AB23A012	1st Floor	CO2	2	Basic Service
013 - CO2 - switch Room	AB23A013	switch Room	CO2	2	Basic Service
014 - CO2 - Kitchen	AB23A014	Kitchen	CO2	2	Basic Service
015 - Fire Blanket - Kitchen	AB23A015	Kitchen	Fire Blanket	0	Basic Service
016 - Foam - large Office	AB23A016	large Office	Foam	6	Basic Service
017 - CO2 - Large office	AB23A017	Large office	CO2	2	Basic Service
018 - Foam - Fire/exit	AB23A018	Fire/exit	Foam	6	Basic Service
019 - CO2 - Fire/Exit	AB23A019	Fire/Exit	CO2	2	Basic Service
020 - CO2 - Boiler house	AB23A020	Boiler house	CO2	5	No Access
021 - Foam - Unoccupied Area	AB23A021	Unoccupied Area	Foam	6	Basic Service
022 - CO2 - Unoccupied Area	AB23A022	Unoccupied Area	CO2	2	Basic Service

General Comments

Special Remarks

FIREHØW

FireHow Limited

Suite 10 Avonmore House

15 Church Square

Banbridge BT32 4AP

t 028406 48444 m 44 07846633129

e: colin.bickerstaff@firehow.co.uk

w: www.firehow.co.uk

Company Registration No. NI 648838

VAT No. 280425024

X 1 Double stand
X 1 2 kg co2
X 2 Fire Blankets
X 4 ID signs
All installed at time of service

I/We have inspected and serviced as necessary to BS5306-3 (Uk) and IS 291 (ROI), the fire extinguishers on this certificate.
These were left in good working order, except where indicated on this certificate.
Please Note Comments Listed Under Special Remarks.

Customer Signature:		Inspector's Signature:		Time In:	10:32
Customer Print Name:	Orla McGrath	Print Name:	Paul English	Time Out	11:24
Position:	Supervisor				

FIREHØW

FireHow Limited

Suite 10 Avonmore House

15 Church Square

Banbridge BT32 4AP

t 028406 48444 m 44 07846633129

e: colin.bickerstaff@firehow.co.uk

w: www.firehow.co.uk

Company Registration No. NI 648838

VAT No. 280425024

Photos

